



## Consumer Confidence Report for Calendar Year 2022

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

<b>Public Water System ID Number</b>	<b>Public Water System Name</b>		
AZ04-13062	Bradshaw Mountain View Water		
<b>Contact Name and Title</b>	<b>Phone Number</b>	<b>E-mail Address</b>	
Stuart McLean	(800)315-5333	info@southwesternutility.com	
We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact Bradshaw Mountain View Water at (800)315-5333 for additional opportunity and meeting dates and times.			

### Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

<b>Our water source(s):</b>	Ground Water – Aqua Fria Basin
-----------------------------	--------------------------------

### Drinking Water Contaminants

**Microbial Contaminants:** Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

**Inorganic Contaminants:** Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

**Pesticides and Herbicides:** Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

**Organic Chemical Contaminants:** Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

**Radioactive Contaminants:** That can be naturally occurring or be the result of oil and gas production and mining activities.



## Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MC L	MCLG	Likely Source of Contamination	
E. Coli	N	0	0	0	0	Human and animal fecal waste	
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MR DL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.5	0.2 – 0.8	4	0	2 monthly	Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MC L	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	7.2	<1 – 7.2	60	N/A	8/2022	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	47.6	3.4 – 47.6	80	N/A	8/2022	Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90 <sup>th</sup> Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	0.045	0	1.3	1.3	6/2022	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	0	0	15	0	6/2022	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MC L	MCLG	Sample Month & Year	Likely Source of Contamination
Alpha Emitters (pCi/L) <small>(This is Gross Alpha 4000)</small>	N	3.1	EPDS003 3.1 EPDS004 0.9 EPDS005 1.9	15	0	2/2019 11/2022 4/2016	Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MC L	MCLG	Sample Month & Year	Likely Source of Contamination
Arsenic <sup>1</sup> (ppb)	N	4.8	EPDS001 4.8 EPDS002 2.5 EPDS003 2.6 EPDS004 2.4 EPDS005 4.7	10	0	2/2019 10/2019 8/2022 11/2022	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Barium (ppm)	N	0.028	EPDS001 0.005 EPDS002 0.028 EPDS003 0.009 EPDS004 0.019 EPDS005 0.003	2	2	2/2019 10/2019 11/2022	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	N	3.2	EPDS001 3.2	100	100	9/2016	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	N	0.37	EPDS001 0.22 EPDS002 0.37 EPDS003 0.28 EPDS004 0.26 EPDS005 0.37	4	4	2/2019 10/2019 11/2022	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm)	N	7	EPDS001 4.9 EPDS002 4.6 EPDS003 2.1 EPDS004 3.5 EPDS005 7	10	10	2/2022 8/2022 11/2022	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	N	42	EPDS001 42 EPDS002 41 EPDS003 34 EPDS004 31 EPDS005 41	N/A	N/A	7/2021 2/2022 8/2022 11/2022	Erosion of natural deposits

<sup>1</sup> **Arsenic** is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

<sup>2</sup> **Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.